Portable Appliance Inspection and Test Record

REPORT NO.

COMPANY NAME & SITE ADDRESS:	JAMES CONNAN 13/41 PILRIG HEIGHTS, EDINBURGH, EH6 5FG
CONTRACTOR'S DETAILS	GLOBE ELECTRICAL, EDINBURGH LTD. 14A DALKEITH ST, EDINBURGH EH15 2HR
TEST EQUIPMENT: Make, Model and Serial Number	ETHOS 9125
COMPETENT PERSON	NAME (BLOCK CAPITALS): THOMAS McGUIRK (SIGNATURE)

Site	Appliance Description	Appliance No.	VISUAL CHECKS					ELECTRICAL TESTS						Comments	Date of Test	Pass (P) or Fail (F)
			Class (I, II, etc)	Fuse Rating (A)	Pass / Fail (✓) (✗)			Earth Bond		Insulation	Functional / Load Test					
					Plug	Lead	Casing	Test Current (A)	Resistance (Ω)	MΩ	kA	Leakage	Sub Leakage			
	MORRISONS KETTLE	1	I	13	✓	✓	✓		0.09	19.99		0.10			23/12/23	P
	ONNTOASTER	2	I	13	✓	✓	✓		0.10	19.99		0.10			23/12/23	P
	PANASONIC MICROWAVE	3	I	13	✓	✓	✓		0.08	19.99		0.10			23/12/23	P
	BEKO WASHING MACHINE	4	I	13	✓	✓	✓		0.12	19.99		0.12			23/12/23	P
	FRIDGEMASTER F/F	5	I	13	✓	✓	✓		0.10	19.99		0.10			23/12/23	P
	BREVILLE IRON	6	I	13	✓	✓	✓		0.10	19.99		0.10			23/12/23	P
	PANASONIC TV	7	II	13	✓	✓	✓			19.99		0.10			23/12/23	P
	GOOD HOME LAMP	8	II	3	✓	✓	✓			19.99		0.10			23/12/23	P
	GOOD HOME LAMP	9	II	3	✓	✓	✓			19.99		0.10			23/12/23	P
	GOOD HOME LAMP	10	II	3	✓	✓	✓			19.99		0.10			23/12/23	P
	GOOD HOME LAMP	11	II	3	✓	✓	✓			19.99		0.10			23/12/23	P
	DYSON VACCUM	12	II	13	✓	✓	✓			19.99		0.10			23/12/23	P

1710

This form is based on the model shown in Appendix 6 of BS 7671: 2008